

# Attestation

## BREEAM International

On 19 December 2019, Eurofins Product Testing A/S received a sample of coating with the product name:

**AITHON A90H**

supplied by

**Aithon Ricerche International**

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort GOLD version 6.0: EN 16516, EN 16402 ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2, respectively (See test report no. 392-2019-10545301\_A\_EN and 392-2019-00545303\_XI\_EN).

- **Evaluation of the emission and content test results according to the basic level emission criteria (table 17) and VOC content criteria (table 19, coatings) of: BREEAM Int.: Hea 02 Indoor air quality:**

- 
- Carcinogenic substances were not detectable after 28 days ( $< 0.001 \text{ mg/m}^3$ ).
  - The sum of VOC ("TVOC") after 28 days was below the limit of  $1 \text{ mg/m}^3$ .
  - Formaldehyde after 28 days was below the limit of  $0.06 \text{ mg/m}^3$ .
  - VOC content of less than  $100 \text{ g/L}$ .

---

**The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).**

27 March 2020



Malene Laugesen  
Analytical Service Manager



Janne Rothmann Norup  
Analytical Service Manager